



Carbondale Central Laboratory
 2401 S. McLaughery Road
 Carbondale, Illinois 62901

Phone: 618-457-4613 Ext 223
 Fax: 618-457-2639
 Laboratory Superintendent: Kimberly A. Cole
 IOPH Certified Laboratory 12502 EPA Lab Number 00012



Laboratory Report Serial Number: 1302017004 Page 1 of 2

Electronic Signature: Kimberly A Cole Reviewed data Date: 11/20/2017

NELAP ACCREDITED NUMBER 100481

Field Report: These test results relate only to the samples submitted. Interpretation and advisories are the responsibility of the client. "N/A" indicates analytical method does not apply to this sample.

Galatia Elementary School

Address: 200 N. Hickory
 City, State, Zip: Galatia, IL 62935

Sample Number	Sample Description	Date Collected	Time Collected	Dishwashing received	Presv. date	Act. criteria	Calc. Factor	Factor Last used	Date Time Analyzed
1	111617011 Basement Far west Fountain	11/11/2017	10:05 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9.00PM	11/28/17 10:25AM
2	111617012 Basement Far west Fountain	11/11/2017	10:05 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:00PM	11/28/17 10:25AM
3	111617013 Basement Midwest Fountain	11/11/2017	10:10 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:00PM	11/28/17 10:25AM
4	111617014 Basement Midwest Fountain	11/11/2017	10:10 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:00PM	11/28/17 10:25AM
5	111617015 Basement East Fountain	11/11/2017	10:15 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:00PM	11/28/17 10:25AM
6	111617016 Basement East Fountain	11/11/2017	10:15 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:00PM	11/28/17 10:25AM
7	111617017 Basement Kitchen	11/11/2017	10:20 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:01PM	11/28/17 10:25AM
8	111617018 Basement Kitchen	11/11/2017	10:20 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:01PM	11/28/17 10:25AM
9	111617019 1st Floor Fountain East	11/11/2017	10:25 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:05PM	11/28/17 10:25AM
10	111617020 1st Floor Fountain East	11/11/2017	10:25 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/16/2017	9:05PM	11/28/17 10:25AM

Sample acceptance Requirements	Sample acceptance
Date and Time from bottle match	YES
Proper bottle received	YES
Sample temperature taken upon receipt	YES
Bottle received in good condition	YES
Paperwork complete	YES
No leaks or damage	YES
Bottle filled with proper volume	YES
Sample received within hold times	YES

Sample Collector

Sample No.	Sample Description	Lead (Pb) ug/L	Qualifier	Analyst	Matrix	Method of analysis	Lead (Pb) MRL	Turbidity, NTU (if the sample turbidity is >1.0 NTU, the sample must be tested per the method)	Sample acceptance requirements met: YES/No met NO (Specify)
111617011	Basement Far west Fountain	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.20	YES
111617012	Basement Far west Fountain	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.18	YES
111617013	Basement Midwest Fountain	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.18	YES
111617014	Basement Midwest Fountain	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.17	YES
111617015	Basement East Fountain	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.18	YES
111617016	Basement East Fountain	< 1.00		ES	Drinking water	EPA 200.8	1.0	10.0	YES
111617017	Basement Kitchen	1.10		ES	Drinking water	EPA 200.8	1.0	0.54	YES
111617018	Basement Kitchen	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.18	YES
111617019	1st Floor Fountain East	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.16	YES
111617020	1st Floor Fountain East	< 1.00		ES	Drinking water	EPA 200.8	1.0	0.16	YES



Carbondale Central Laboratory
 2401 S. McLafferty Road
 Carbondale, Illinois 62901

Phone: 618-457-2413 Ext 223
 Fax: 618-457-2499
 Laboratory Superintendent: Kimberly A. Cole
 DPH Certified Laboratory 17502 EPA Lab Number 00012

Laboratory Report Serial Number: 1302017004 Page 2 of 2

Electronic Signature: Kimberly A Cole Reviewed data Date: 11/30/2017

NELAP ACCREDITED NUMBER 100461

Final Report: Please read fountain notes only as no samples submitted. Interpretation and submission per the responsibility of the client. "or" indicates optional equipment for the method.

Galatia Elementary School
 Address: 200 N. Hickory
 City: Sun, Zie Galatia, IL 62935

Sample number	Sample Description	Date collected	Time Collected	Duration received	Print date	Am. (cc)	Case/Fault	Print	Print
11	1st Floor West Fountain	11/11/2017	10:30 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/10/2017	9:10PM	11/28/17 10:25AM
12	1st Floor West Fountain	11/11/2017	10:30 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/10/2017	9:10PM	11/28/17 10:25AM
13	2nd Floor East Fountain	11/11/2017	10:35 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/10/2017	9:15PM	11/28/17 10:25AM
14	2nd Floor East Fountain	11/11/2017	10:35 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/10/2017	9:15PM	11/28/17 10:25AM
15	2nd Floor West Fountain	11/11/2017	10:40 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/10/2017	9:17PM	11/28/17 10:25AM
16	2nd Floor West Fountain	11/11/2017	10:40 AM	11/16/17 2:00PM	11/16/2017	250 mL	11/10/2017	9:17PM	11/28/17 10:25AM
17									
18									
19									
20									

Sample acceptance Requirements
 Date and Time from bottle receipt
 Proper bottle received
 Sample temperature taken upon receipt
 Bottle received in good condition
 Paperwork complete
 No leaks or damage
 Bottle filled with proper volume
 Sample received within hold times

Sample No.	Sample Description	Lead (ppb) ug/L	Sample Collector	Qualifier	Analyst	Matrix	Method of analysis	Lead (ppb) MRL	Turbidity, NTU (if the sample turbidity is < 0.1 NTU the sample was analyzed per the method)	Sample acceptance requirements met (Yes/No) (see: 7.1)
111617021	1st Floor West Fountain	< 1.00	Melody Bond		ES	Drinking water	EPA 200.8	1.0	0.17	yes
111617022	1st Floor West Fountain	< 1.00	Melody Bond		ES	Drinking water	EPA 200.8	1.0	0.17	yes
111617023	2nd Floor East Fountain	< 1.00	Melody Bond		ES	Drinking water	EPA 200.8	1.0	0.12	yes
111617024	2nd Floor East Fountain	< 1.00	Melody Bond		ES	Drinking water	EPA 200.8	1.0	0.15	yes
111617025	2nd Floor West Fountain	< 1.00	Melody Bond		ES	Drinking water	EPA 200.8	1.0	0.15	yes
111617026	2nd Floor West Fountain	< 1.00	Melody Bond		ES	Drinking water	EPA 200.8	1.0	0.16	yes